BOARD OF EDUCATION
Mrs. Patricia Lock-Dawson,
President
Dr. Angelov Farooq,
Vice President
Mrs. Kathy Allavie,
Clerk
Mr. Tom Hunt
Mr. Brent Lee
Members

Riverside Unified School District

OPERATIONS DIVISION
3070 WASHINGTON STREET
RIVERSIDE, CALIFORNIA 92504

MAINTENANCE & OPERATIONS
(951) 788-7496 X84001
FAX: (951) 778-5646

DAVID C. HANSEN, ED.D.
District Superintendent

RUSD
Innovation in Education

SUBJECT: LEAD SAMPLING RESULTS - Ramona High School

On October 13th, 2017, California Assembly Bill 746 Section 116277 of the Health and Safety Code (HSC 116277) was passed, mandating the lead testing of community water systems for all public Kindergarten through grade 12 (K-12), preschools and child day care facilities before July 1st. 2019.

In California, the State Water Resources Control Board (SWRCB) oversees public water systems to ensure the water they provide is tested and safe according to the regulations set forth by the State and Federal Safe Drinking Water Acts. Regulations pursuant to those acts include a regulation adopted by the United States Environmental Protection Agency (USEPA) and the SWRCB to control lead levels in drinking water. Lead in drinking water is typically found at its highest levels upon a *first draw.* A first draw is a sampling of water taken from a fixture after the water has been stagnated for an extended period of time, i.e., overnight. Each sample taken at sample locations are taken as a first draw in order to capture and record the highest level present at a sampling location.

On November 29th, 2018, Riverside Public Utilities collected water samples at 6 locations throughout the site. Below are the laboratory results of those samples.

Sample	Fixture type	Location	Action Level	Result
1	Drinking Fountain	Gym Ext. Girls Locker. Rm Tall Left	Below	ND
2	Drinking Fountain	Admin Interior Tall Left	Below	ND
3	Drinking Fountain	Band Room Lobby Int. Bottle Filler	Below	ND
4	Drinking Fountain	Stadium @ Concession Ext. Tall Right	Below	ND
5	Drinking Fountain	ROTC Exterior of Room 362	Below	ND
6	Sink Faucet	Stadium Con. Bldg. Int. Ice Room	Below	ND

**ND= Not detected, ppb=part per billion (equivalent to approx. 1 water drop in an Olympic size pool)*